



Hyderabad Karnataka Education Society's

# MAHADEVAPPA RAMPURE MEDICAL COLLEGE

## DEPARTMENT OF MICROBIOLOGY

Date : 8/1/22

To, Principal  
Dr. K. Krishna  
Kondriva Vidyalaya  
Kalaburgi - 585102

Bacteriological examination of water from RO

Sources of water —

Time of collection 10.00 AM Date 06/1/22

### REPORT

(Presumptive coliform test)

Sl. No.	No. of Organisms/100ml.	Remarks
1.	0 (Zero) organisms (100ml)	
2.		
3.		
4.		
5.		
6.		
7.		

Interpretation : Excellent (water potable for drinking purpose)  
(Bacteriologically)

Class I Presumptive Coliform Count/100ml.

1. Excellent	- 0
2. Satisfactory	- 1 - 3
3. Suspicious	- 4 - 10
4. Unsatisfactory	- More than 10

Micro No. 30

Rec. No. : 1977

Date : 06/1/22

  
Prof & Head  
Dept. of Microbiology  
M.R. Medical College Kalaburagi